Constancy of Performance Certificate

No. 0370-CPR-7448

Date issued: 17/04/2026
First issue date: 10/10/2025
Expiry date: 31/03/2029

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Shenzhen HTI Sanjiang Electronics Co., Ltd.

3/F., Guangcai Xintiandi Mansion, Nanshan Road, Nanshan District, Shenzhen, Guangdong, 518054, China

Manufactured at the production plant

Building 1B, Hongao Industrial Estate (Hongfa High-tech Industrial Park), Crossing of Genyu Road and Nanming Road, Gongming Street, Guangming New District, Shenzhen, Guangdong, China

PRODUCT

Fire detection and fire alarm system

- ☐ Manual call points

Model: C9060T

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-11:2001, EN 54-11:2001/A1:2005

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

The validity of this certificate remains in effect as long as the harmonised standard, the construction product, the AVCP methods, and the manufacturing conditions at the plant are not significantly modified, unless the certificate is suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex, whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment

LGAI Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)

ENAC
CERTIFICACIÓN
ISO 17065
Nº12 / C-PR054

Check the status of this certificate

Certificate

LGAI Technological Center S.A. (APPLUS)
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)

Technical annex Ed. 1
10/10/2025
0370-CPR-7448

Technical Annex

Annex according to EN 54-11:2001, EN 54-11:2001/A1:2005

Fire detection and fire alarm system. Part 11: Manual call points

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Marking and data	4.2	Pass
Normal condition	4.3.1	Pass
Alarm condition	4.3.2	Pass
Indicators for alarm condition	4.4	Pass
Reset facility	4.5	Pass
Test facility	4.6	Pass
Shape, dimensions and colors	4.7.2	Pass
Symbols and lettering	4.7.3	Pass
Protection against accidental operation	4.7.4	Na
Environment category	4.7.5	Pass Type A
Additional requirements for software controlled manual call points	4.8	Na
Operational performance test	5.2	Pass
Function test	5.3	Pass
Test facility test (operational)	5.4	Na
Reliability test (endurance)	5.5	Pass
Variation of supply parameters	5.6	Pass
Dry heat (operational)	5.7	Pass
Dry heat (endurance)	5.8	Na
Cold (operational)	5.9	Pass
Damp heat, cyclic (operational)	5.10	Pass
Damp heat, cyclic (endurance)	5.11	Na
Damp heat, steady state (endurance)	5.12	Pass
SO2 corrosion (endurance)	5.13	Pass
Shock (operational)	5.14	Pass
Impact (operational)	5.15	Pass
Vibration, sinusoidal (operational)	5.16	Pass
Vibration, sinusoidal (endurance)	5.17	Pass
Electromagnetic compatibility (EMC) (operational)	5.18	Pass
Enclosure protection	5.19	Na

PASS; NPD = No Performance Determined, NA = Not Apply

Accessories	
DZ-9060K	Supporting base