BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2111

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

A9020T Addressable Heat Detector
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Shenzhen HTI Sanjiang Electronics Co., Ltd
3/F, Guangcai Xintiandi Mansion
Nanshan Road, Nanshan District,
Shenzhen
Guangdong
518054
China

and produced in the manufacturing plant(s):

Shenzhen HTI Sanjiang Electronics Co., Ltd
Guangming Factory
Building 1B, (Hongfa High-tech Industrial Park)
Hongao Industrial Estate, Crossing of Genyu Road and Nanming Road
Gongming Street, Guangming New District,
Shenzhen, Guangdong
518000, China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors - Point heat detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 05 November 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P. Halligan.

P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of Issue: 4 November 2022

Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2022

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2111

A9020T Addressable Heat Detector

Note:
Meets the requirements of EN 54-5 for Category A2

Base
DZ-912

P. Halligan.

P Halligan, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020
Date of issue: 4 November 2022
Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2022