BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F4642

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

SEC1000 Single Loop Analogue Addressable Control and Indicating Equipment
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Shenzhen HTI Sanjiang Electronics Co., Ltd
3/F, Guangcai Xintiandi Mansion,
Nanshan Road,
Nanshan District, Shenzhen,
Guangdong,
China

and produced in the manufacturing plant(s):

Shenzhen HTI Sanjiang Electronics Co., Ltd
Guangming Factory
Building 1B, (Hongfa High-tech Industrial Park)
Hongao Industrial Estate
Crossing of Genyu Road and Nanming Road,
Gongming Street, Guangming New District
Shenzhen, Guangdong
518132, China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 30 August 2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 30 August 2022

Date of Issue: 2 September 2022

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2022

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4642

SEC1000 Single Loop Analogue Addressable Control and Indicating Equipment

Incorporating the following modules:

SEC1000_CB	Main Control Board
SEC1000_MB	IO Board
PMC_01	Power Management Control Board
LRS-75-24	Meanwell Power Supply

Certified with the following options with requirements from EN54-2:

7.8	Output to fire alarm devices
7.11	Delays to outputs
8.3	Fault signals from points
9.5	Disablement of addressable points
10	Test condition

Notes:
1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13.

E. Mattie-Suleiman, Certification Engineer
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 30 August 2022
Date of issue: 2 September 2022
Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2022