LPCB®

Certificate of Product Approval

Shenzhen HTI Sanjiang Electronics Co., Ltd

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1426h-(cl-1)	04	3/F, Guangcai Xintiandi Mansion Nanshan Road Nanshan District, Shenzhen Guangdong, 518054 China

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS
Alarm Warning Devices A9092T C9092T A9093T A9093G C9097B (refer to Appendix for details)	EN 54-3:2014 + A1:2019

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

Signed for BRE Global Ltd	Z Major Verifier	24 August 2026 Date of Issue

28 February 2020
Date of First Issue

This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford,WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

Copyright © 2026 BRE. All Rights Reserved

LPCB®

Appendix to Certificate No: 1426h-(cl-1)

ISSUE
04

Shenzhen HTI Sanjiang Electronics Co., Ltd

Certified Product	Description	LPCB Ref No.
A9092T	Intelligent Type A (Indoor) Red Sounder with Visual Indicator (DZ-9091K Base) Notes: Meets the requirements of EN 54-3 at the following tone: Sweep tone 667Hz-2kHz @0.21Hz	1426h/01
C9092T	Conventional Type A (Indoor) Sounder Beacon (DZ-A92 Base) Notes: Meets the requirements of EN 54-3 at the following tone: Tone 1: Sweep 667Hz-2200Hz	1426h/02
A9093T	Addressable Type A (Indoor) Sounder Beacon Notes: Meets the requirements of EN 54-3 at the following tone: Tone 2: Sweep 1800Hz-3470Hz	1426h/03
A9093G	Addressable Type B (Outdoor) Sounder Beacon Notes: Meets the requirements of EN 54-3 at the following tone: Tone 2: Sweep 1800Hz-3470Hz	1426h/04
C9097B	Conventional Type A (Indoor) Sounder Base Notes: Meets the requirements of EN 54-3 at the following tone: Tone 1: Sweep 667Hz-2000Hz	1426h/05

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

Signed for BRE Global Ltd	Z Major Verifier	24 August 2026 Date of Issue

28 February 2020
Date of First Issue

This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford,WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

Copyright © BRE. 2026 All Rights Reserved

Appendix to Certificate No: 1426h-(cl-1)

ISSUE
04

Shenzhen HTI Sanjiang Electronics Co., Ltd

Products Extras

DZ-9091K

DZ-A92

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

Signed for BRE Global Ltd	Z Major Verifier	24 August 2026 Date of Issue

28 February 2020
Date of First Issue

This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford,WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

Copyright © BRE. 2026 All Rights Reserved