Certification

of Components and Systems

This certification is valid only for the specified component/system as submitted for testing

- together with the parts listed in enclosure 1
- documented in the technical documents according to enclosure 2
- for the use in the specified fire protection and security installations.

When using the subject of the certification the notes of enclosure 3 shall be observed.

This certificate may only be reproduced in its present form without any modifications including all enclosures. All changes of the underlying conditions of this certification shall be reported at once to the VdS certification body including the required documentation.

This certificate confirms compliance with the listed basic requirements and does not confirm the suitability of the product in a system according to a set of rules for planning and installation by VdS.

Holder of the Certification

Shenzhen HTI Sanjiang Electronics Co., Ltd
3/F, Guangcai Xintiandi Mansion, Nanshan Road
CN- Nanshan District, Shenzhen, 518054

Certification No.	No. of pages	valid from (dd.mm.yyyy)	valid until (dd.mm.yyyy)
C 226006	4	02.04.2026	01.04.2030

Subject of the Certification

Input-/output device
A9056T

Use

in automatic fire detection and fire alarm systems

Basis of the Certification

EN 54-18:2005 + AC:2007

Issue Date: 02.04.2026

Dr. Reinermann
Managing Director

i. V. Hesels
Head of Certification Body

VdS Schadenverhütung GmbH
Amsterdamer Str. 174
D-50735 Köln

A company of the German Insurance Association (GDV) accredited by DAkkS as certification body for fire protection and security products

DAkkS Deutsche Akkreditierungsstelle D-ZE-11149-01-01

to Certification No. C 226006 dated 02.04.2026

The subject of the certification comprises the following parts.

Description of Subject	Type	Holder's Registration No.	Certification No.
Input-/Output Device, Base	A9056T DZ-9056		

Enclosure 2 Sheet 1

to Certification No. C 226006 dated 02.04.2026

The subject of the certification is described by the following documents.

Type of Document	Identification of document	Date/ Revision	Pages
Test Reports			
	TE107635-1001 Issue 1	05.07.2018	
	SW107635-1001 Issue 1	24.04.2018	
A9056T User manual	30037200-220525	22.05.2025	2
A9056T Product data sheet	DPAJ3.623.152JS	V1.0	1
A9056T Product label drawing	139042907	V1.0	1
A9056T General assembly	ROHS3.623.328	V1.0	1
A9056T Mechanical drawing	ROHS8.074.094	V1.0,	6
	DPAJ8.074.068	V1.0,	
	DPAJ8.641.071	V1.0,	
	DPAJ8.080.086	V1	
	ROHS.387.062		
A9056T PCB layout	ROHS7.820.907/V1.6	V1.7	2
A9056T Circuit diagram	ROHS3.623.382DL	V1.7	1
A9056T PCBA BOM	ROHS5.064.940	V1.7	3
A9056T Parts list	ROHS3.623.382MX	V1.2	1
A9056T Software Details	DPAJ3.623.152CT	V1.0	10
DZ-9056			
DZ-9056 General assembly	ROHS3.691.059	V1.0	1
DZ-9056 Mechanical drawing	ROHS8.071.077	V1.0,	4
	DPAJ8.078.108	V1.0,	
	DPAJ8.078.109	V1.0,	
	DPAJ8.387.049	V1	
DZ-9056 Parts list	ROHS3.691.059MX	V1.1	1

to Certification No. C 226006 dated 02.04.2026

Instructions for the application of the subject of certification (see enclosure 1).

Type A9056T is an input/output device for operation in automatic fire detection and fire alarm systems.

Technical data (manufacturer's specifications):

Supply voltage (DC):	18 V to 28 V
Quiescent current (loop):	0.8mA
Alarm current (loop):	5mA
Supported protocols:	Addressable XXX
Output capacity:	1A@30DC